



IRANIAN PETROLEUM STANDARD

IPS

MATERIAL AND EQUIPMENT STANDARD
FOR
VALVES

FIRST EDITION
MARCH 2003

DEPUTY MINISTER
FOR
ENGINEERING & TECHNOLOGY
RESEARCH AND STANDARDS

FOREWORD

This Standard is intended to be used within and for Iranian Ministry of Petroleum (N.I.O.C, N.I.G.C, N.P.C., N.I.O.R.D.C. and other affiliate organizations and companies) and has been prepared on the basis of the recognized standards, scientific publications, technical documents, accumulated knowledge and experiences in petroleum industries at national and international levels.

Iranian Petroleum Standards are prepared by Iranian Petroleum Standards Organization reviewed and amended by the relevant technical standard committees to incorporate acceptable comments made by oil, gas and petrochemical experts.

Standards are finally approved by the "Standards High Council" of Iranian Ministry of Petroleum.

Iranian Petroleum Standards (IPS) are subject to amendment withdrawal, if required, thus the latest edition of IPS shall be applicable.

Any comment or recommendation submitted to the "Iranian Petroleum Standards Organization" will be evaluated in the relevant technical committee and will be considered in the next revision, upon approval.

GENERAL DEFINITIONS:

Throughout this Standard the following definitions shall apply.

"COMPANY" : Refers to one of the related and/or affiliated companies of the Iranian Ministry of Petroleum such as National Iranian Oil Company, National Iranian Gas Company, National Petrochemical Company etc.

"PURCHASER" : Means the "Company " Where this standard is part of direct purchaser order by the "Company", and the "Contractor" where this Standard is a part of contract documents.

"VENDOR" and **"SUPPLIER"** : Refers to firm or person who will supply and/or fabricate the equipment or material.

"WILL" : Is normally used in connection with the action by the "Company" rather than by a contractor, supplier or vendor.

"MAY" : Is used where a provision is completely discretionary.

"SHOULD" : Is used where a provision is advisory only.

"SHALL" : Is used where a provision is mandatory.

IRANIAN PETROLEUM STANDARDS.

No. 19, Street 14, North Kheradmand Karimkhan Avenue, Tehran, Iran.

Tel. : 66153055

: 88810460

Fax. : 88810462

March 2003

MATERIAL AND EQUIPMENT STANDARD
FOR
VALVES

FIRST EDITION

MARCH 2003

This Standard is the property of Iranian Ministry of Petroleum. All rights are reserved to the owner. Neither whole nor any part of this document may be disclosed to any third party, reproduced, stored in any retrieval system or transmitted in any form or by any means without the prior written consent of the Iranian Ministry of Petroleum.

0. INTRODUCTION

This Standard covers the minimum requirements for purchasing conventional valves to be used in oil, gas and petrochemical industries. The Standard contains seven parts. Each enquiry consists of two parts; part one general requirements and the other part pertaining to requirements for one of the following valves:

Part 1	General requirements
Part 2	Gate valves
Part 3	Globe valves
Part 4	Plug valves
Part 5	Butterfly valves
Part 6	Check valves
Part 7	Ball valves

Valves contained in this Standard have end connections as follows:

- Flanged end
- Butt welding end
- Socket welding end
- Threaded end
- Special end

Note: This first (1) edition, which is a new revision of this standard with the same title and number, has been technically revised, cancels and replaces the original (0) edition which now is withdrawn.

Guidance for Use of this Standard

The amendments/supplements to API 6D (1994 Edition), API 600 (1997 Edition), API 602 (1998 Edition) ... Given in this standard are directly related to the equivalent sections or clauses in these standards.

The following annotations, as specified hereunder, have been used at the bottom right hand side of each clause or paragraph to indicate the type of change made to the equivalent clause or paragraph of reference standards.

- Sub. (substitution)** : "The clause in reference standard is deleted and replaced by the new clause in this Standard"
- Del. (Deletion)** : "The clause in reference standard is deleted without any replacement".
- Add. (Addition)** : "A new clause with a new number is added".
- Mod. (Modification)** : "Part of reference standard is modified and/or a new description and/or statement is added to that clause".

PART ONE
GENERAL REQUIREMENTS

CONTENTS :	PAGE No.
1. GENERAL	4
1.1 Scope.....	4
1.2 Conflict requirements	4
1.3 References	4
2. DESIGN	7
3. MATERIAL	9
4. INSPECTION.....	10
5. TESTING	10
6. REPAIRS.....	10
7. FINISHING, PAINTING (AND/OR COATING).....	11
8. IDENTIFICATION.....	11
9. PACKAGING.....	11
10. HANDLING AND SHIPPING	12
11. GUARANTEE.....	12
12. REJECT CAUSES	12
13. DOCUMENTATIONS AND LANGUAGE	12
14. DRAWING AND DATA	13

1. GENERAL

1.1 Scope

This part of standard covers general requirement(s) for purchasing valves specified in part two thru seven.

1.2 Conflict requirements

The valve(s) offered by the vendor shall be in compliance with the requirement(s) of this Standard. If requirement(s) of this Standard differs from or is in conflict with other purchasing documents, the vendor shall clearly indicate points of conflict and request the Company for clarification and comments.

The Company's comments shall be fully considered and incorporated in the final specifications.

In case that no comment(s) is given by the Company, the followings will take precedence in the order of priority as indicated hereunder:

- a) Purchase order.
- b) This Standard specifications.

1.3 References

Throughout this Standard the following dated and undated standards/codes are referred to. These referenced documents shall, to the extent specified herein, form a part of this standard. For dated references, the edition cited applies. The applicability of changes in dated references that occur after the cited date shall be mutually agreed upon by the Company and the Vendor. For undated references, the latest edition of the referenced documents (including any supplements and amendments) applies.

ANSI (AMERICAN NATIONAL STANDARD INSTITUTE)

ASME (AMERICAN SOCIETY OF MECHANICAL ENGINEERS)

- B 1.20.1 "Pipe Threads, General Purpose"
- B 16.1 "Cast-Iron Pipe Flanges and Flanged Fittings"
- B 16.4 "Cast-Iron Threaded Fitting"
- B 16.5 "Pipe Flanges and Flanged Fittings"
- B 16.10 "Face-to-Face and End-to-End Dimensions of Valves"
- B 16.11 "Forged Fittings, Socket Welding and Threaded"
- B 16.15 "Cast Bronze Threaded Fittings"
- B 16.24 "Cast Copper Alloy Pipe Flanges and Flanged Fittings"
- B 16.25 "Butt Welding Ends"
- B 16.34 "Valves-Flanged, Threaded and Welding End"
- B 16.42 "Ductile Iron Pipe Flanges and Flanged Fittings"

- B 31.1 "Power Piping"
- B 31.3 "Chemical Plant and Petroleum Refinery piping"
- B 31.4 "Liquid Transportation System for Hydrocarbon, Liquid Petroleum Gas, Anhydrous Ammonia and Alcohol"
- B 31.8 "Gas Transmission and Distribution Systems"
- B 36.10 "Welded and Seamless Wrought Steel Pipe"

ASTM (AMERICAN SOCIETY FOR TESTING AND MATERIALS)

- B 650 "Standard Specification for Electrodeposited Engineering Chromium Coatings on Ferrous Substrate"
- B 656 "Standard Guide for Autocatalytic (Electroless) Nickel-Phosphorus Deposition on Metals for Engineering Use"
- E 112 "Standard Test Methods for Determining Average Grain Size"
- E 446 "Standard Reference Radiographs for Steel Casting up to 2in. (51 mm) in Thickness"

API (AMERICAN PETROLEUM INSTITUTE)

- 594 "Check Valves: Wafer, Wafer-Lug and Double Flanged Type"
- 598 "Valve Inspections and Testing"
- 599 "Metal Plug Valves-Flanged and Welding Ends"
- 600 "Steel Gate Valves, Flanged and Butt Welding Ends, Bolted and Pressure Bonnets"
- 602 "Compact Steel Gate Valves-Flanged, Threaded, Welding and Extended Body Ends"
- 603 "Class 150, Cast Corrosion-Resistant, Flanged end Gate Valves"
- 605 "Large-Diameter Carbon Steel Flanges"
- 607 "Fire Test for Soft-Seated Quarter-Turn Valve"
- 608 "Metal Ball Valves-Flanged, and Butt-Welding Ends"
- 609 "Butterfly Valves: Double Flanged, Lug and Wafer Type"
- 6D "Pipeline Valves(Gate, Plug, Ball and Check Valves)"
- 6FA "Fire Test for Valves"

ANSI (AMERICAN NATIONAL STANDARD INSTITUTE)

AWWA (AMERICAN WATER WORK ASSOCIATION)

- C 500 "Metal-Seated Gate Valves for Water Supply Service"

- C 501 "Cast-Iron Sluice Gates"
- C 504 "Rubber Seated Butterfly Valves"
- C 507 "Ball Valves, 6 in. Through 48 in. (150 mm. Through 1200 mm.)"
- C 508 "Swing-Check Valves for Water Works Service, 2 in. (50 mm)Through 24 in. (600 mm.) NPS"
- C 509 "Resilient-Sealed Gate Valves for Water Supply Service"

BSI (BRITISH STANDARDIZATION INSTITUTE)

- 1133 "Packaging Code"
- 1868 "Specification for Steel Check Valves (Flanged and Butt-welding Ends) for the Petroleum, Petrochemical and Allied Industries"
- 1873 "Specification for Steel Globe and Globe Stop and Check Valves (Flanged and Butt-Welding Ends) for the Petroleum, Petrochemical and Allied Industries"
- 5151 "Specification for Cast Iron Gate (Parallel Slide) Valves for General Purpose"
- 5152 "Specification for Cast Iron Globe and Globe Stop and Check Valves for General Purpose"
- 5153 "Specification for Cast Iron Check Valves for General Purpose"
- 5154 "Specification for Copper Alloy Globe, Globe Stop and Check and Gate Valves"
- 5155 "Specification for Butterfly Valves"
- 5157 "Specification for Gate (Parallel Slide) Valves for General Purposed"
- 5159 "Specification for Cast Iron and Carbon Steel Ball Valves for General Purpose"
- 5351 "Specification for Steel Ball Valves for the Petroleum, Petrochemical and Allied Industries"
- 5352 "Specification for Steel Wedge Gate, Globe and Check Valves 50 mm and Smaller for the Petroleum, Petrochemical and Allied Industries"
- 6755 Part 2 "Testing of Valves Specification for Fire-Type Testing Requirements"

MSS (MANUFACTURERS STANDARDIZATION SOCIETY)

- SP-6 "Standard Finishes for Contact Faces of Pipe Flanges and Connecting End Flanges of Valves and Fittings"
- SP-25 "Standard Marking System for Valves, Fittings, Flanges and Unions"
- SP-44 "Steel Pipeline Flanges"
- SP-70 "Cast Iron Gate Valves, Flanged and Threaded Ends"

SP-78	"Cast Iron Plug Valves, Flanged and Threaded Ends"
SP-80	"Bronze Gate, Globe, Angle and check Valves"
SP-81	"Stainless Steel, Bonnet less, Flanged Knife Gate Valves"
SP-84	"Steel Valves, Socket Welding and Threaded Ends"

NACE (NATIONAL ASSOCIATION OF CORROSION ENGINEERS)

MR 0175	"Sulfide Stress Cracking Resistant Metallic Materials for Oil Field Equipment"
---------	--

SIS (SWEDISH STANDARD INSTITUTE)

05-5900	"Preparation of Steel Substrates before Application of Paints and Related Products"
---------	---

2. DESIGN

2.1 Primarily this specification covers conventional gate, globe, ball, plug, butterfly and check valves. Other types of valves shall conform to this specification in so far as applicable.

2.2 Where pressure containing parts have been specified as forged, substitution of casting is not permitted without prior approval of the Company.

2.3 Drain taps shall be factory fitted with forged metal plug(s) per ANSI B 16-11 and of the same basic material as the valve body. They shall be made up leak tight.

2.4 All power actuated valves shall have capability of being operated with an auxiliary device such as hand wheel (oriented as specified, hydraulic hand pump etc.

2.5 The maximum operating force for manually operated valves shall not exceed 350 N. However, for DN 200 (NPS8) and larger the maximum operating force may increase to 450 N, during seating and unseating of the valve.

2.6 Valve(s) gear boxes shall be dust and weather-proof, filled with suitable water resistant lubricant. Lubricant SAE No. shall be specified in quotation and shall also be shown on gear-box name plate. Gear operators shall have self-locking gears. The gear operator shall be provided with a torque limiting device on the input shaft that will prevent damage to the drive train.

2.7 Valves shall be provided with a position indicator. Showing open position in the direction of flow and close position perpendicular to the direction of flow. The shut and open terms in English shall be permanently indicated in a visible location.

2.8 Clockwise rotation of the hand wheel/wrench shall close the valve. The diameter of the hand wheel or length of the wrench shall not exceed 800 mm.

2.9 Hydraulic, pneumatic or electric actuator shall be supplied by the valve manufacturer when specified. Manufacturer of the actuator and actuating mechanism shall be approved by the Company in advance.

2.10 When chain wheels are specified for valve actuation, chain guide shall be included. Clamp-on type chain wheels are not permitted.

2.11 When extended stem is specified, the valve shall have extended bleed/vent, balancing and lubricating lines.

2.12 Valve of 500 kg and heavier shall be fitted with lifting lugs, valve support and leveling base. Their design and position shall be agreed with the Company.

2.13 The stem and stem head shall be sized to provide adequate strength under the most severe combination of operating condition. The weakest point shall always be outside of the stem seal.

2.14 All flanged gate, globe, ball and check valves with ring joint facing should also have ring joint bonnet, or purchaser approved equal.

2.15 Fire-safe or fire-tested design unless otherwise specified. all valves shall have fire- safe or fire-tested design and capability of meeting the requirements of API 6 FA, BS 6755 part 2 and API 607 as applicable.

2.15.1 The following terminology shall be used:

- a) Fire safe design : A design that by nature of its features and properties is capable of passing a fire test.
- b) Fire tested design : A design subjected successfully to fire testing.

2.15.2 Soft-seated valves shall have a fire-tested design. Metal-seated valves and hand wheel or gear operator shall have a fire-safe design.

2.15.3 Any special provision for protecting actuator system against fire shall be stated in the purchase requisition.

2.15.4 Fire testing shall be done in accordance with API 6 FA or BS 6755 part 2 or API 607. Existing certificate to these Standard is acceptable.

2.16 Dimensions

2.16.1 Face to face (end to end) dimensions of valves shall be as per related standards. Dimensions of valves not listed in the related standard shall be in accordance with ANSI/ASME B 16.10 or established by agreement.

2.16.2 End flanges dimensions shall conform to the following standards:

- a) Steel and nickle base flanges up to DN 600 (NPS 24) per ANSI/ASME 16.5
- b) Steel and nickle base flanges over DN 600 (NPS 24) per MSS-SP-44
- c) Cast iron flanges per ANSI/ASME-B 16.1
- d) Bronze flanges per ANSI/ASME-B 16.24

2.16.3 Flanges surface finishing shall conform to standard MSS-SP-6. Where a smooth finish is specified, the gasket contact surface roughness shall be 100-150 Ra in accordance with MSS-SP-6.

2.16.4 Butt welding ends shall conform to standards:

- per ANSI/ASME B 16.25,31.1,31.3,31.4,31.8
- AS Applicable

2.16.5 Socket welding ends shall conform to standard ANSI/ASME-B 16.11

2.16.6 Threaded ends shall conform to the following standards:

- a) Steel and nickel base valves per ANSI/ASME-B 1.20.1
- b) Cast iron valves per ANSI/ASME-B 16.4
- c) Bronze valves per ANSI ASME-B 16.15

2.17 Pressure-temperature ratings of valves shall conform to the following standards:

- a) Steel and nickle base alloys per ANSI/ASME B 16.34 or related standards of valves as applicable
- b) Ductile iron valves per ANSI/ASME-B 16.42
- c) Cast iron valves per ANSI/ASME- B 16.1
- d) Copper alloy valves per BS-5154
- e) Bronze valves per ANSI/ASME-B 16.24

Allowable operating pressures and temperatures for valves made of materials not covered by mentioned standards shall be determined by calculations in accordance with an agreed pressure vessel design standard.

2.18 Non-metallic parts of valves intended for hydrocarbon gas service at pressure of PN 100 (class 600) or above shall be resistant to explosive decompression.

2.19 The valve body shall have sufficient rigidity to withstand a compressive axial thrust exerted by the connected piping, equal to the design pressure multiplied by the area of the maximum valve bore, without permanent distortion of the body or affecting the free movement and sealing of the seats.

2.20 The manufacturer shall provide the following data to the purchaser:

- the flow coefficient Kv;
- the breakway thrust or torque for new valve;
- the maximum allowable stem thrust or torque on the valve and, if applicable, the drive train.

3. MATERIAL

3.1 Where valves are specified "No Copper Permitted" this shall be understood to mean that no copper (except trace element) or copper-bearing alloy material shall be used in the construction of these valves. This includes internal and external parts such as trim, backseat, yoke bushing and gland-follower.

Exceptions: Alloy 20, Monel, 17-4 PH, 17-7 PH when specified.

3.2 Monel body material for screwed, socket-weld end and butt-weld end valves shall be of a weldable composition.

3.3 Unless otherwise specified, all austenitic stainless steel valves shall be furnished in the solution annealed condition.

3.4 Material composition of welding end valves

The chemical composition (by ladle analysis) of valve bodies with butt weld or socket weld ends shall be restricted as follows:

a) Carbon and carbon-manganese steels

Maximum carbon content shall not be more than 0.25% and carbon equivalent (C.E.) shall not exceed 0.42%.

Where:

$$\text{C.E.} = \text{C} + \frac{\text{Mn}}{6} + \frac{\text{Cr} + \text{Mo} + \text{V}}{5} + \frac{\text{Cu} + \text{Ni}}{15}$$

b) Chromium-molybdenum steels

Steels with 2% cr and less

Carbon max. = 0.20%

Steels with more than 2% cr.

Carbon max.= 0.15%

c) Austenitic stainless steel

valves which are to be welded should be manufactured from a low carbon grade (e.g. 304 L, 316 L) or stab lised grade (e.g. 321)

3.5 Materials for pressure-containing and pressure-controlling parts and bolting shall meet the requirements of NACE MR01 75 if sour service is specified.

4. INSPECTION

The inspection shall be as per requirements of API standard 598, section 2.0. Manufacturer shall be prepared for inspection of the valve by Inspector.

5. TESTING

5.1 All valves shall be tested in accordance with procedures laid down in their relevant standard(s).

5.2 The type or style of valve stem packing used during hydrotest shall be the same as that finally supplied with the valve.

6. REPAIRS

6.1 Casting Repairs

Repair of casting is not permitted.

6.2 Forging Repairs

Method(s) of repair shall have prior approval of the purchaser.

7. FINISHING, PAINTING (AND/OR COATING)

7.1 Unless otherwise specified, after final testing, all valves shall be internally and externally dried, and internally

coated with grease or sealant.

7.2 After protection of all machined and threaded external surfaces and covering all valve(s) nozzles and openings, the equipment shall be blast cleaned to Swedish standard SIS-05-5900 grade, SA 2½. This shall be followed by the coating or painting as specified by purchaser.

7.3 All machined or threaded surfaces shall be protected from corrosion with a rust preventive material which shall not become fluid and run off at a temperature less than 82°C.

7.4 Unless otherwise specified by purchaser, bronze and stainless steel valve shall not be painted or coated.

7.5 Particular attention shall be given to protection of Austenitic stainless-steel valves from Chloride attack in salt contaminated atmospheres.

8. IDENTIFICATION

8.1 Manufacturer's Markings

Each valve shall be marked in strict accordance with MSS-SP-25.

8.2 Contract Tagging

8.2.1 Each valve shall be fitted with a rust-resistant metal tag securely attached to it with sufficient twists of stainless steel wire. The same shall apply to other items which are noted as metal tagged in the item description.

8.2.2 Tags shall normally be attached to the gland bolting. Tags on valves that do not have gland bolting may be attached to the hand-wheel or other appropriate location.

8.2.3 Tags shall not be attached through bolt-holes of end flanges.

8.2.4 Each tag shall be clearly stamped with item number and other identification number as specified by Company, including body and trim materials.

8.2.5 If the valve is for special service, an additional tag shall be used spelling out this requirement, e.g. "for Chlorine Service".

8.2.6 The minimum dimension(s) for tags and wire are as follows:

- a) Size of tag Round 40 mm (1½ inches) dia.
 Rectangular 12 x 70 mm (½ x 2¾ inches)
- b) Thickness of tag 1.3 mm minimum
- c) Lettering height 6 mm (¼ inches) minimum
- d) Wire diameter 1.3 mm minimum

9. PACKAGING

Valve packaging shall meet the requirement of BS 1133 Section 2.

10. HANDLING AND SHIPPING

10.1 Gate and Globe valves shall be in closed position for shipment, plug and ball valves shall be in open position and flapper of check valves shall be protected from movement during shipment. Butterfly valve's disc shall be unseated before shipment.

10.2 All soft seated valves shall be packed in open position.

10.3 Valves shall be shipped with a correct stem packing installed and with a gland-follower sufficiently tightened to prevent in-service leaking.

10.4 Openings shall be closed with a metal, wood or plastic protector to exclude dirt and other foreign matter from the interior of the valve; for flanged valves these shall be no smaller than the flange-outside diameter.

10.5 Provision shall be made to prevent disposition of the valves closure element during shipment.

11. GUARANTEE

11.1 The manufacturer/supplier shall guarantee his equipment during commissioning and for one year operation starting from the completion of seven days continuous service test "in site" at full load, against the following defects:

- a) All operational defects.
- b) All material defects.
- c) All constructional and design defects.

The shipment and storage time shall be assumed to be 18 months.

11.2 All defective parts shall be replaced by the supplier in the shortest possible time, free of charge. The cost of dismantling, reassembling at site and all transportation involved shall be borne by the supplier.

11.3 The supplier shall guarantee the provision of spare parts with the same standard specification and tests of the original equipment to the Purchaser for a minimum period of 10 years from the date of dispatch of the valve.

11.4 In the event that the supplier cannot supply the required spares (whether of his own manufacture or others) within this period of time, the cost of complete replacement units shall be borne by the supplier.

12. REJECT CAUSES

The valve may be rejected if measurement, inspection and/or testing, reveal discrepancies between quoted figures in purchase documents and those obtained actually.

13. DOCUMENTATIONS AND LANGUAGE

All Vendor supply documentations including all correspondence, literature, drawings and data shall be as per ISO documentation and drawing standards, and shall be prepared in English.

Offers in languages other than English shall not be accepted.

Drawings, certificates and other documents shall be submitted by manufacturer in standard robust files. The files containing the documents shall have proper classification and numbering for easy reference.

14. DRAWING AND DATA

The supplier should provide the following drawings and data at no extra cost to the Purchaser.

14.1 With Quotation**4 sets of:**

- a) Comprehensive catalogues, technical data, outline drawings, derating curves, proposed test procedure, service facilities etc., of the equipment offered and its various components:
- b) Preliminary connection and wiring diagrams, if applicable, dimensional and cross sectional drawings.
- c) Declaration of conformation with the set standards and/or clear indication of deviations from the standards and specification.
- d) Reference list showing the location of successful continuous operation for at least two years in major oil or pipeline companies, of the offered valve(s).
- e) Recommended commissioning and 3 years running consumables and spare parts separately listed, numbered, referenced, duly priced and approximate normal delivery time and stocking points given.
- f) Recommended special tools for maintenance and installation with price list.

Note:

The quotation will be rejected as incomplete if the above required information are not included.

14.2 After Placing Order (60 Days At Latest)**5 sets of:**

- g) Shipping dimensions (length, width and height) and weight with shipping schedule.
- h) Piping, wiring and dimensional/outline drawings and foundation plans, if applicable, specially given size, location of various connections to the outside equipment and recommended installation details for purchaser's approval.
- i) Proposed tests procedure for Purchaser's approval.
- j) Reproduces (1 set only) of above mentioned drawings after approval duly certified by the manufacturer/supplier. No dimensional changes will be allowed after approval.
- k) Prints of certified drawings as well as agreed and approved test procedure.
- l) Detailed manufacturing and testing program for the equipment and its components. Monthly progress report shall be submitted to the Purchaser at the end of each calendar month.

14.3 Before Delivery**15 sets:**

- m) Codes and standards compliance certificates;

- n) Final connection and wiring diagrams;
- o) Installation, operation and maintenance manuals;
- p) Factory test certificates, including test data and calculated results (when ready);
- q) Illustrated and numbered parts list and final revision of 3 years running spare parts list. (Refer to the attached spare parts list and interchangeability record, SPIR).

The above drawings and data, provision of which is the manufacturer/supplier's obligation, shall include but not limited to the followings:

- i) Certificate of shop inspection;
- ii) Welding procedure and welder qualifications;
- iii) Non-destructive test certificates;
- iv) Certified reports giving chemical analysis and physical properties of steel and lining materials;
- v) Hydrostatic test certificates;
- vi) Certified dimensions and sectional drawings.

PART TWO
GATE VALVES

CONTENTS :	PAGE No.
1. SCOPE	17
2. DESIGN AND MANUFACTURING.....	17
3. SUPPLEMENT TO REFERENCE STANDARDS.....	18
SECTION ONE SUPPLEMENT TO API-6D (1994).....	19
SECTION TWO SUPPLEMENT TO API-600 (1997).....	21
SECTION THREE SUPPLEMENT TO API-602 (1998).....	23

1. SCOPE

This part of Standard covers minimum requirements for design, material, inspection and tests of gate valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of gate valves shall generally meet the requirements of the following standards:

2.1 All classes of carbon and Ferritic alloy steel DN 25 (NPS 1) and higher, stainless steel and nickel base alloy, flanged and butt welding ends double disc and wedge gate valve
Per API-STD-600

or API-STD-6D

as Applicable

2.2 Unless otherwise specified, smaller than DN 80 (NPS 3), flanged ends gate valves (compact design) may be furnished to API 602.

2.3 PN 20 (ANSI 150) and PN 50 (ANSI 300) stainless steel and nickel base alloy flanged ends, wedge gate valves.
Per API-STD. 602

or API-STD. 603 as Applicable

2.4 PN 130 (ANSI 800), Carbon, Ferritic alloy and stainless steel and nickel base alloy, threaded and socket welding ends, wedge gate valves up to DN 50 (NPS 2) Per : API-STD. 602

2.5 Carbon, Ferritic alloy, stainless steel, through conduit gate valves Per API-STD. 6D

2.6 Parallel slide steel gate valves Per BS-STD. 5157

2.7 Stainless steel bonnet less, wafer (knife) gate valves Per MSS-SP-81

2.8 Cast Iron, flanged ends, wedge gate valves Per MSS-SP-70

2.9 Cast Iron, threaded ends, wedge gate valves Per MSS-SP-80

2.10 Cast Iron, parallel slide gate valves Per BS-STD. 5151

2.11 Cast Iron gate valves for water and sewerage Per ANSI/AWWA-C500

2.12 Cast Iron sluice gate valves for water supply and waste water services Per ANSI/AWWA-C501

2.13 Cast Iron resilient seated gate valves for general water and sewerage Per ANSI/AWWA-C509

2.14 Copper alloy gate valves up to DN 100 (NPS 4) PN 20 (ANSI 150) and PN50 (ANSI 300)

Per BS-STD. 5154

2.15 Bronze valves up to and including DN 80 (NPS 3) Per MSS-SP-80

3. SUPPLEMENT TO REFERENCE STANDARDS

SECTION ONE API-6D (1994)

SECTION TWO API-600 (1997)

SECTION THREE API-602 (1998)

SECTION ONE SUPPLEMENT TO API-6D (1994)

1.1 This Standard applies to through conduit gate valves, with flanged or butt-welding ends, in nominal sizes DN50 (NPS 2) and larger in PN20 (ANSI 150) to PN 420 (ANSI 2500) designed and manufactured to API 6D. **(Sub.)**

2.10 Pressure Relief

2.10.1 If specified for valves DN 100 (NPS 4) and over a bleed connection position G or H per ANSI B 16.34 Fig. 1 shall be provided to permit valve testing in situ: Bleed fitting shall have an anti-blow out design. **(Add.)**

2.10.2 Body cavity over pressure shall be prevented by self-relieving seat rings/assemblies if specified. Self relieving seat rings shall relieve at a body cavity differential pressure not exceeding 30% of the valve PN (ANSI) pressure rating class at 38°C (100°F). **(Add.)**

2.11 Drain and By-Pass Connections

The following paragraph shall be added to existing clause:

All double block and bleed valves shall have a vent and a drain. The drain connection shall be at the lowest possible position on the valve body, the vent connection at the highest possible position. DN 100 (NPS 4) valves and smaller may have a combined drain and vent connection, which shall be at the lowest possible position. The drain connection shall have a drain valve. The vent connection shall have a bleed fitting of an anti-blow out design. **(Mod.)**

2.15 Stem and Stuffing Box

2.15.1 Gate valve DN 50 (NPS 2) and larger with rating PN 50 (ANSI 300) and over shall be equipped with lantern rings in the stuffing box where a DN 8 (NPS ¼) tapped hole completed with plug shall be provided for sealant injection and drain. **(Add.)**

2.15.2 Stem sealing should be by mechanically energized "U" or "V" rings with lantern rings included to allow secondary sealant injection. **(Add.)**

2.15.3 Diametral clearances of the parts around the stem shall be such that stem can never touch components that may damage the stem. **(Add.)**

2.15.4 The rising stem shall be fully enclosed by a dust proof stem protector or Yoke tube and extended with an exposed indicator rod. **(Add.)**

2.16 Seat Rings

2.16.1 When specified, both a soft seal and a metal-to-metal seal shall be provided with the gate. Screwed seat rings shall be renewable.

2.16.2 When specified, the seat rings shall be spring energized to ensure upstream sealing at low differential pressures. For sealing at higher differential pressures the seat rings shall be line-pressure energized. **(Add.)**

2.16.3 Differential pressure shall also move the gate into the downstream seat to give a downstream seal. The design of seat ring and body shall be such that entrapment of solids present in the fluid will not obstruct free movement of the seat rings and will not reduce any spring action. **(Add.)**

2.17 Underground Valves

2.17.1 Valves to be installed under ground may have a stem extension as specified in purchase document. The design of the stem extension shall be subject to the approval by the purchaser. The

extension shall be fully enclosed. The enclosure shall be water-proof and have a pressure relief system to prevent pressure-build-up in the event of a stem seal failure. **(Add.)**

2.17.2 When extended stem is specified, extension lines for drain, vent and sealant injection shall adequately be clamped to the valve body or stem extension to avoid damage due to vibration and reaction forces of sealant injection or scalping medium. Drain and vent lines shall be the same size as the connection to the valve body. The extension lines shall be suitable for the valve class (or sealant injection pressure for the sealant line, whichever is the higher). Extension lines shall allow disconnection at the body cover flange level. For sealant injection lines, unions may be used. The extension lines shall end approximately 100 mm. (4 inches) below the top flange of the stem extension. **(Add.)**

2.17.3 Double valving is required in vent and drain extension lines, one valve close to the connection to the valve body and one valve at the end of the extension line, at the highest possible position. The latter shall be blanked-off. The sealant injection lines shall have a grease fitting at the highest point. **(Add.)**

2.18 Stem yoke nut of DN80 (NPS 3) and larger for PN 420 (ANSI 2500) and DN 150 (NPS 6) and larger for PN 100 (ANSI 600), PN 150 (ANSI 900) and PN 250 (ANSI 1500) shall be equipped with anti friction thrust bearing. **(Add.)**

2.19 The body-bonnet joint design shall be bolted with a minimum of four cap screws, studs or stud bolts. Cap screws shall be suitable for external wrenching only. **(Add.)**

2.20 Unless otherwise specified, all butt welding ends of gate valves, shall be furnished with two pipe transition pieces welded to each end of the valve. The diameter of each transition piece shall be equal to valve nominal diameters. The length of each piece shall be equal to valve DN (NPS) or 300 mm (12 inches) whichever is greater. The material and wall thickness of transition piece shall be same as those of connecting pipe. The transition piece shall be shop welded and fully radiographed with X-ray prior to valve test. Post weld heat treatment, if required, shall be conducted after welding of transition pieces. **(Add.)**

3.3 Non-Metallic Parts

3.3.1 The section size of elastomers in PN 100 (ANSI 600) and above shall be less than 7 mm (0.3 in.) to withstand explosive decompression. An elastomer may only be used for the valve seats in PN 20-100 (ANSI 150-600). **(Mod.)**

3.4 Other Parts

3.4.1 The possibility of galling between component of similar metallic composition shall be considered by the manufacturer. **(Mod.)**

3.4.2 Where electro less nickel plating is specified for corrosion protection, local overlays or bushing may be used as an alternative after Company approves that nickel plating can not be offered. The following areas would need protection:

- Adjacent to seat rings and seat springs (seat pockets)

- Back seat

(Mod.)

4.1.1 Gate Valves

The following sub clause shall be added to existing clause:

d. Unless otherwise specified, valves shall be of rising stem type.

(Mod.)

SECTION TWO SUPPLEMENT TO API-600 (1997)

1.3.1 The following sentence shall be added to existing clause:

The manufacturer shall specify the rated pressure for soft seats at temperature above 50°C.

(Mod.)

2.1.9 The following sentences shall be added to existing clause:

Swaged/rolled/pressed in seat rings are not acceptable. Threaded-in seat rings shall be properly secured.

(Mod.)

2.2.5

The following paragraphs shall be added to existing clause:

- Rolled/pressed-in back seat bushing are only acceptable when additionally secured against loosening. (see 2.12).

- Threaded-in back seat bushing shall be properly secured. (see 2.12).

-Flat seating faces are not acceptable.

(Mod.)

2.3.8

The following paragraphs shall be added to existing clause:

- Rolled-in facing rings are not acceptable.

- 13 cr and Austenitic stainless steel deposition on carbon steel material, without a buffer layer is not acceptable.

- Sprayed deposit layers are not acceptable, other method shall be approved by the Purchaser.

(Mod.)

2.11 Soft Sealing

2.11.1 Soft sealing rings may be placed in either the body seats or the closure member, but the latter option is preferred.

2.11.2 A soft sealing arrangement shall have a secondary or primary metal to metal sealing arrangement incorporated in the design.

(Add.)

2.12 Securing

2.12.1 Positively securing against loosening shall primarily be done by means of tack-welding.

(Add.)

2.12.2 When valve parts are made from different materials or when materials are non-weldable other methods of locking may be acceptable depending upon the method and place of execution. These methods are subject to approval by the purchaser.

The other methods may be as follow:

a) Locking ring

b) Retaining strip or tab

c) Screws with close fit thread

d) Spring tension pins (Add.)

2.12.3 Screwed-in seat rings of martensitic (13 Cr) material shall be secured by means of a steel tab of which one end is positioned in the driving slot of the seat and the other end welded to the valve body. (Add.)

2.12.4 Spring tension pins are not allowed for locking of internals. (Add.)

3.5 Yoke

3.5.1 The yoke shall have provisions for an extended stem or actuator/gear box mounting flange incorporated in the design when applicable or when specified. (Add.)

3.5.2 When a yoke sleeve is retained to the yoke by means of a retaining nut, the latter shall be secured to the yoke (see 2.12). (Add.)

3.11 Stem Packing

Packing design temperature should be corrected to 538°C (1000°F). (Mod.)

SECTION THREE SUPPLEMENT TO API-602 (1998)

1.4 For nickel/copper alloy valves, API 602 shall be the guidance for design, dimension, marking, inspection and testing. **(Add.)**

4.2 End Connections

4.2.11 End flanges or stubs of nickel/copper alloy valves shall be cast or forged integral with the valve body, unless attachment by welding is approved by the Purchaser. **(Add.)**

4.13 Seat Rings

The following sentence shall be added to existing clause:

Screwed-in seat rings shall be properly secured, in the body by means of tack-welding. **(Mod.)**

PART THREE
GLOBE VALVES

CONTENTS :	PAGE No.
1. SCOPE	26
2. DESIGN AND MANUFACTURING.....	26
3. SUPPLEMENT TO REFERENCE STANDARD (BS 1873-1975)	26

1. SCOPE

This part of Standard covers minimum requirements for design, material inspection and tests of globe valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of globe valves shall generally meet the requirements of the following standards:

2.1 Carbon and alloy steel and nickel base flanged ends and butt-welding ends

Per BS 1873

2.2 Carbon and alloy steel socket welding, threaded, flanged and butt welding ends up to DN50

Per BS 5352

2.3 Cast Iron, flanged ends

Per BS 5152

2.4 Copper alloy, flanged and screwed ends up to DN100

Per BS 5154

3. SUPPLEMENT TO REFERENCE STANDARD (BS 1873-1975)

1. SCOPE

The following sentence shall be added to existing clause:

Unless otherwise specified, globe valves shall be straight pattern type. **(Mod.)**

8.10.1 Rolled in seat rings are not acceptable for DN80 (NPS 3) and larger **(Add.)**

8.10.2 Screwed-in seat rings of 13% chromium seat material shall be secured by means of a steel tab of which one end is positioned in the driving slot of the seat and the other end welded to the valve body. **(Add.)**

18. SOFT SEAL RINGS

18.1 The first sentence of existing clause shall be substitute with the following:

Soft sealing rings may be placed in either the body seat or the closure member, but the following would be preferred:

Flow to open in the body seat

Flow to close in the closure member **(Mod.)**

PART FOUR
PLUG VALVES

CONTENTS :	PAGE No.
1. SCOPE	29
2. DESIGN AND MANUFACTURING	29
3. SUPPLEMENT TO API-6D 1994	30

1. SCOPE

This part of Standard covers the minimum requirements for design, material inspection and tests of plug valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of plug valves shall generally meet the requirements of the following standards except for those noted in this specification.

- 2.1 Steel and nickel base valves, flanged and butt welding ends Per API-STD-599
- 2.2 Steel and socket welding end threaded ends Per MSS-SP-84 or API 602 when specified
- 2.3 Steel pipeline valves flanged and butt welding ends Per API-6D
- 2.4 Ductile iron plug valves, flanged ends Per API-599
- 2.5 Cast iron plug valves Per MSS-SP-78

2.6 Unless otherwise specified in the item description, Lubricated plug valves shall be suitable for the following temperatures.

- Standard taper plug type to 176°C (350°F).
- Inverted taper plug type to 260°C (500°F).

2.7 Unless otherwise specified in the item description, inverted lubricated plug valves shall have the following stem

type.

<u>SIZE</u>	<u>PRESSURE CLASS</u>	<u>STEM TYPE</u>
PN (ANSI RATING)		
DN £ 100 (NPS 4)	20 & 50 (150 & 300)	PLAIN
150-600 (NPS 6-24)	20 & 50 (150 & 300)	THREADED
40-500 (NPS1½-20)	150 (900)	THREADED
40-400 (NPS1½-16)	250 (1500)	THREADED
40-100 (NPS1½-4)	420 (2500)	THREADED
15-25 (NPS ½-1)	ALL CLASSES	THREADED STEM AND COVER

2.8 Dynamic balanced plugs require prior Purchaser approval.

2.9 Unless otherwise specified in the item description, the plugs shall be equipped with bush bearings at the top and bottom.

2.10 Top or bottom plate shall be provided for in-line maintenance without removing valve body from the line.

3. SUPPLEMENT TO API-6D 1994

The following clauses/sections of API 599-1994 shall be considered as part of the API 6D-1994 for plug valves specifications.

2.3 Cover

2.4 Plug stem

2.5 Gland

2.6 Bolting

2.7 Operation

3.0 Material

Note:

Clause 3.1 of API 6D has preference to clause 3.2 of API 599 for pipeline plug valves.

PART FIVE
BUTTERFLY VALVES

CONTENTS :

PAGE No.

1. SCOPE	33
2. DESIGN AND MANUFACTURING.....	33
3. SUPPLEMENT TO REFERENCE STANDARD API 609-1997(BUTTERFLY VALVES, LUG-TYPE AND WAFER-TYPE)	33

1. SCOPE

This part of Standard covers minimum requirements for design, material, inspection and tests of butterfly valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of butterfly valves shall generally meet the requirements of the following standards:

2.1 Double flanged, low-leakage rate and regulating valves BS 5155.

2.2 Lug type (single flange) API 609.

2.3 Wafer type API 609 and when specified BS 5155.

2.4 Rubber seated butterfly valves for water services Per ANSI/AWWA C-504

3. SUPPLEMENT TO REFERENCE STANDARD API 609-1997

(BUTTERFLY VALVES, LUG-TYPE AND WAFER-TYPE)

1.3 Unless otherwise specified valve shall be of top and bottom guided. (Add.)

4.2.1 The following sentence shall be added to existing clause:

Both wafer and lug valve types shall have one-piece cast bodies to provided sufficient strength to resist pipeline stresses. (Mod.)

4.5.6 Drive pins

Drive pins shall be locked in place to provide a strong and rigid disc-to-shaft connection. (Add.)

4.5.7 Thrust bearings

a) Rugged, low friction thrust bearings shall be provided for positive centering of the disc in the seat.

b) Thrust bearings shall be located at the top and bottom of the disc to withstand shaft thrust in either direction. (Add.)

4.5.8 Shaft journal bearings

a) Bearings shall be located on top and bottom of the disc to support shaft loads.

b) The bearings shall provide maximum corrosion resistance, withstand high loads and assure lasting, easy operation of the valve.

c) The manufacturer shall demonstrate any necessary lubrication provision in the proposal. (Add.)

4.5.9 Shaft

a) Shaft shall be ground finish to minimize bearing and packing wear.

b) Unless otherwise specified, shaft shall be of one-piece design to provide continuously contact through the disc to assure maximum strength and rigidity. (Add.)

4.7.5 Separate seat rings-mechanically retained metal.

- a) The seat retaining ring shall securely hold the seat in place and provide maximum surface face gasket contact.
- b) The retaining ring shall be held in place with machine screws to assure positive seat alignment both before and after installation.
- c) The retaining ring on the lug type bodies shall be mechanically fastened to body to provide a fully rated shut off on dead end service in either direction.
- d) Retaining ring and contact face of the body shall have a phonograph finish faces. **(Add.)**

4.8.5 Each valve shall have a rugged, universal actuator mounting bracket to allow field interchangeability of all manual and powered actuators. **(Add.)**

4.8.6 Actuator bracket bearing

- a) Lubricated, corrosion resistant bearing shall be provided into the actuator mounting bracket to support the valve shaft and assure smooth and easy valve operation. **(Add.)**

4.8.7 Actuator drive shaft

It shall be equipped with radial and thrust bearings and shall demonstrate the arrangement and any provision for lubrication in the proposal. **(Add.)**

4.8.8 Manual valve

Unless otherwise specified, double lead threads shall be provided to reduce the number of turns to operate the manual valves. **(Add.)**

4.8.9 Stop nut

- a) A threaded traveling nut shall be provided to move along the shaft which, as the actuator drive shaft rotates it reaches the actuator housing.
- b) Contact between the nut and housing shall provide a positive adjustable stop to any desired open position.
- c) A guide rail shall also be provided to prevent the stop nut from rotating on the input shaft.
- d) Stop nut shall be easily adjustable when guide rail is removed. **(Add.)**

4.8.10 Actuator drive arm

- a) A steel drive arm shall be provided and keyed to the valve shaft.
- b) The threaded drive arm nut shall be provided and supported with bearings. **(Add.)**

4.8.11 Valve position indicator shall be provided. **(Add.)**

4.10 Disc

- a) Unless otherwise specified disc face shall have concave feature to reduce turbulence and minimizing dynamic torque.
- b) Disc shall be cast and carbon steel disc shall have a nickel edge. **(Add.)**

5.2.2 The following paragraphs shall be added to existing clause

Seat design shall have the following features:

- 1) Protected in open position:** Seat shall be out of the flow path and protected by the retaining ring.
- 2) Positive shut off:** As the disc closes, it shall move into the seat and expand the seat rings to provide a positive seal.

Non-metallic seats shall be elastically supported to assure lasting tight shut off.

- 3) Pressure sealing:** It shall provide a tighter sealing as pressure increases in either direction. **(Mod.)**

5.4 Packing or Shaft Seal Materials

The following paragraph shall be added to existing clause.

- Each valve shall be equipped with multiple ring, packing follower, packing gland flange.
- Gland flange shall be easily adjustable without disassembling of the valve or removal of the actuator. **(Mod.)**

PART SIX
CHECK VALVES

CONTENTS :

PAGE No.

1. SCOPE	38
2. DESIGN AND MANUFACTURING	38
3. SUPPLEMENT TO REFERENCE STANDARD (API 6D-1994).....	38

1. SCOPE

This part of Standard covers minimum requirement for design, material, inspection and tests of check valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of check valves shall generally meet the requirements of the following standards:

2.1 Steel and nickel base swing type pipeline check valves flanged and butt welding ends or wafer type:

Per API-SPEC-6D

2.2 Carbon steel and alloy steel, wafer, single-and dual-plate check valves

Per API 594

2.3 Steel and nickel base, screwed and socket welding ends, piston, ball, disk type

up to DN 50 (NPS 2)

BS-1868, BS-5352 As Applicable

2.4 Steel and nickel base, flanged and butt welding ends, swing type check valve

up to DN 600 (NPS 24)

BS-1868

up to DN 50 (NPS 2)

BS-5352

2.5 Cast iron, swing type and lift type check valves

up to DN 400 (NPS 16)

Per BS-5153

2.6 Copper alloy, flanged, screwed, capillary and compression ends, swing, piston and disk type check valve

up to DN 100 (NPS 4)

Per BS-5154

2.7 Cast iron check valves for water services, swing type, flanged and mechanical joints:

Per ANSI/AWWA C-508

3. SUPPLEMENT TO REFERENCE STANDARD (API 6D-1994)

2.15 Seat Rings

2.15.1 Unless otherwise specified, seat rings shall be replaceable in the field without removing valve body from the

line except for the following cases:

- a) Austenitic steel valves may have integral seats.
- b) Austenitic or hard-facing (body) seat material may be deposited only on separate steel seat rings. The minimum finished thickness of the deposit shall be 1.6 mm. **(Add.)**

2.15.2 Body seat shall be inclined at an angle of approximately 5° from the vertical to facilitate closing and to prevent chatter. **(Add.)**

2.15.3 Seat rings may be shoulder or bottom seated and may be screwed in, welded in or, with prior approval of the purchaser, rolled in. **(Add.)**

2.15.4 Threaded seat rings shall be provided with lugs or slots to facilitate removal. **(Add.)**

2.15.5 A resilient seat shall be bonded or molded into the seat ring. **(Add.)**

2.16 Disk spindle shall be electro less nickel plated and equipped with bush bearing complete with cage. **(Add.)**

2.17 Outside Attachment

2.17.1 If specified in the purchase order and if the design permits, the hinge pin may be extended through the body of

the valve. **(Add.)**

2.17.2 An outside lever with adjustable weight, damping device, fusible link or locking device shall be provided to control the movement of the disk. **(Add.)**

2.18 Loading Spring **(Add.)**

Consideration should be given to providing a spring to ensure positive closing of the valve where there is a low differential pressure or when the process fluid is highly viscous.

PART SEVEN**BALL VALVES**

CONTENTS :	PAGE No.
1. SCOPE	42
2. DESIGN AND MANUFACTURING	42
3. SUPPLEMENT TO REFERENCE STANDARDS	42
- SECTION ONE-SUPPLEMENT TO API-6D (1994)	43
SECTION TWOSUPPLEMENT TO BS 5351 (1986, AMDT 1990)	48

1. SCOPE

This part of Standard covers minimum requirements for design, material, inspection and tests of ball valves to be installed both in on-plot and off-plot piping. For general requirements refer to part 1 of this Standard.

2. DESIGN AND MANUFACTURING

Design and manufacturing of ball-valves shall generally meet the requirements of the following standards:

2.1 Steel and nickel base ball valves flanged and butt welding ends.

- PN 20 (ANSI 150) and PN 50 (ANSI 300) up to DN 300 (NPS12) incl.:

API 6D

or API 608 As Applicable

BS 5351

- DN 50 (NPS 2) and larger PN 20 (ANSI 150) up to PN 420 (ANSI 2500):

API 6D

or BS 5351 As Applicable

- PN 100 (ANSI 600) and over API 6D

- All Pipeline Valves API 6D

2.2 Steel and nickel base ball valves, threaded ends and socket welding ends:

Per BS-5351

or MSS-SP-84 As Applicable

2.3 Cast Iron Valves Per BS-5159

2.4 Ball valves for water services up to 20 bar (300 PSI) CWP per ANSI/AWWA-C-507.

3. SUPPLEMENT TO REFERENCE STANDARDS

SECTION ONE API-6D (1994)

SECTION TWO BS 5351 (1986, AMDT 1990)

- SECTION ONE

-SUPPLEMENT TO API-6D (1994)

1.1 This specification applies to soft and metal seated ball valves, full and reduced bore, anti-static design, double block and bleed facility, with flanged or butt welding ends, in nominal size DN50 (NPS 2) and larger in PN20 (ANSI 150) to PN420 (ANSI 2500), designed and manufactured to API 6D-1994. This document is a supplement to API 6D and shall be governed where conflict occurs with API 6D. **(Sub.)**

2.1 Valve covered by this Standard shall be furnished in the following pressure ratings:

ANSI RATING	PN RATING
150	20
300	50
400	64
600	100
900	150
1500	250
2500	420

(Sub. except for "NOTE")

2.5 End Flanges

The following sub clauses shall be added to existing clause.

f. The body end flanges shall be integrally cast, forged, or butt welded to the body or end adaptors.

g. Studded ends are only permitted with prior approval of the Purchaser. **(Mod.)**

2.6 Welding Ends

2.6.1 The supplier shall ensure that weld ends of valve are physically and chemically compatible with the adjoining pipe. **(Add.)**

2.6.2 Where valve weld ends are not chemically compatible or are of a bevel thickness exceeding 1.5 times the pipe wall thickness, transition pieces having physical and chemical characteristics compatible with the adjoining pipe shall be provided. **(Add.)**

2.6.3 The manufacturer of valves with soft seals shall advise on the field welding of valves with shorter pup pieces. The purchase requisition shall state the required dimensions and materials of the pup pieces and whether or not they will be supplied free issue. **(Add.)**

2.6.4 The manufacturer shall advise on the suitability of proposed pup pieces with regard to pressure testing. **(Add.)**

2.6.5 There shall be a smooth ID transition between welding end and pup piece. For full-bore valves the transition taper shall be at least 1:4. **(Add.)**

2.6.6 Post weld heat treatment, if required, shall be conducted after welding of transition pieces and before pressure testing. **(Add.)**

2.10 Pressure Relief

2.10.1 Body cavity over-pressure shall be prevented by self-relieving seat rings/assemblies unless otherwise specified. (Add.)

2.10.2 A pressure relief hole in the ball is not allowed, unless otherwise specified or agreed by the Purchaser. (Add.)

2.10.3 Self-relieving seat rings shall relieve a body cavity differential pressure not exceeding 30% of the valve class rating pressure at 38 °C (100°F). (Add.)

2.11 Drain and Bypass Connections

2.11.1 All Trunnion-mounted valves shall have a vent and drain. The drain connection shall be at the lowest possible position on the Valve body, and the vent connection at the highest possible position. DN 100 (NPS 4) valves and smaller may have a combined drain and vent connection, which shall be at the lowest possible position. (Add.)

2.11.2 The vent connections shall have a bleed fitting of an anti-blow out design. The drain connections shall have a drain plug or blind flange. (Add.)

2.11.3 No vent or drain are needed for floating ball valves. (Add.)

2.15 Sealant Injection Connections

2.15.1 Unless otherwise specified, valves of DN 150 (NPS 6) and larger shall have sealant injection points to seats and stem seal, connected to the body by NPT threading methods. (Add.)

2.15.2 All sealant injection connections shall incorporate an integral non-return valve, a giant button head and a cover with vent holes that seals-off the fitting by plugging the sealant injection port. (Add.)

2.16 Buried Valves

2.16.1 Valves to be installed in buried lines shall be supplied with a stem extension, whose length is specified in purchase document. (Add.)

The design of the stem extension shall be subject to approval by the Purchaser. (Add.)

2.16.2 The extension shall be fully enclosed. The enclosure shall be water-proof and have a pressure relief system to prevent pressure built up in the event of a stem seal failure. (Add.)

2.16.3 When a relief valve is fitted on a buried installation, the relief valve should be located above ground and discharged in accordance with ANSI B31.4/31.8. (Add.)

2.16.4 Extension lines for drain and sealant injection, adequately clamped to the valve body or stem extension to avoid damage due to vibration and reaction forces of sealant injection or escaping medium. (Add.)

2.16.5 The extension lines shall end approximately 100 mm (4 inches) below the top flange of the stem extension. (Add.)

2.16.6 Double valving is required in vent and drain lines, one valve close to the connection to the valve body and one valve at the end of the extension line, at the highest position; the valve on the extension line shall be blanked-off. The drain valves shall be located above ground and discharged in accordance with ANSI B31.4 or B3.18 as applicable. (Add.)

2.16.7 Valve stem extension shall be detachable for easy replacement. (Add.)

2.17 Ball

2.17.1 The ball shall be one piece casting or a forging. The ball port shall be cylindrical. **(Add.)**

2.17.2 Chromium plating is not acceptable when electroless nickel plating is specified, it shall have final mirror finish preparation and min. Thickness of 25 mm according to ASTM B650 and ASTM B656 respectively. The hardness of plating shall be at least 800 HV. **(Add.)**

2.17.3 A pressure-equalizing path between valve cavity and bore in the open position is not preferred, because the possibility of seat testing in the open position in service is lost. The presence of such a connection shall be indicated in the purchase requisition. **(Add.)**

2.17.4 Unless otherwise agreed with the Purchaser, the ball shall be trunnion mounted, for bore size DN80 (NPS 3) and larger. **(Add.)**

2.18 Seat Rings

2.18.1 Seat rings shall be renewable (except for all-welded body ball valves) and may be a ring with a soft insert positively locked in position. Ring with a soft insert positively locked in position. **(Add.)**

2.18.2 Seat seals shall be:

a) Tight in normal operation.

b) Capable of continued metal to metal operation in event of exposure to fire.

c) Fitted with facility for injection of sealant for continued operation on failure of primary seal. **(Add.)**

2.18.3 The seat rings shall be spring energized to ensure sealing at low differential pressure. For sealing at higher differential pressure the seat rings shall be line pressure energized. **(Add.)**

2.18.4 The design of seat ring and body shall be such that entrapment of solids present in the fluid don't obstruct free movement of the seat rings and not reduce any spring action. **(Add.)**

2.18.5 Full bore valves shall be capable of being pigged, sphered and scraped, regularly without debris being pushed between the valve seats and the ball or into the seating assembly. **(Add.)**

2.18.6 When more consistent wear pattern is desired and also for helping the secondary sealant to be worked fully around the sealing area of the valve after injection, rotating seat rings shall be used with prior Purchaser approval. **(Add.)**

2.19 Stem and stem seal

2.19.1 The stem shall be sized such that both its smallest cross section and connection to the ball shall withstand the maximum side loads and operating torque needed to seal and to operate against the maximum class differential pressure (applied to one or both sides of the valve, whichever case needs the higher torque). **(Add.)**

2.19.2 The stem of actuator-operated valves shall be sized to withstand the maximum output torque of the actuator in addition to side loads due to differential pressure. **(Add.)**

2.19.3 The stem may be integral with the ball or separate. A separate stem shall be held by the body of the valve or stem retaining parts such that a blow-out can not take place. **(Add.)**

2.19.4 Stem retaining parts shall be capable of withstanding the full internal pressure/temperature rating of the valve and the hydrostatic shell test pressure. **(Add.)**

2.19.5 The drive mechanism between stem and ball shall be one of the following methods:

- Slot and tongue
- Drive pins
- Interference fit (shrink fit)
- Interference fit (shrink fit) and drive pins
- Spines **(Add.)**

2.19.6 It shall be impossible to re-assemble the ball and stem such that the stem is 90° out of phase with the ball. **(Add.)**

2.19.7 Diametral clearances of the parts around the stem shall be such that the stem can never touch components that may damage the stem. **(Add.)**

2.19.8 For wrench operated valves, the stem head shall be circular and either have two flats parallel to the valve bore or a keyway in line with the valve bore. Square heads are not allowed. Other construction requires Purchaser approval. **(Add.)**

2.19.9 The method of stem sealing shall be approved by the purchaser. "U" or "V" seals shall be spring energized. Stem seal shall be designed for easy replacement while the valve is in the open position. **(Add.)**

2.19.10 Stem shall be fitted with facility for sealant injection. **(Add.)**

2.20 Design

2.20.1 Two or three piece body forgings are only acceptable if the manufacturer can demonstrate by flange calculations to a national standard acceptable to the Purchaser that the valve shows no relevant detrimental distortion under load. **(Add.)**

2.20.2 The valve body shall have sufficient rigidity to withstand a comprehensive axial thrust exerted by the connected piping, equal to the design pressure multiplied by the area of the maximum valve bore, without permanent distortion of the body or affecting the free movement of the ball and sealing of the seats. **(Add.)**

2.20.3 Bolted covers shall have at least four bolts other methods of attachment shall be subject to prior approval of the Purchaser. **(Add.)**

2.20.4 Bolting of split body flanges shall be stud bolts or other fasteners with prior approval of the Purchaser. **(Add.)**

3.1 Body, Bonnet, Cover, End Flange, and Welding End

3.1.1 Valves made from casting shall be of X-ray quality Class 2 as defined by ASTM E-446 and ASTM E-112. **(Add.)**

3.2 Bonnet and Cover Bolting

3.3 Non-Metallic Parts

3.3.1 Section size of elastomers for resistance to explosive decompression in PN150 (ANSI 900) and above services shall be less than 7 mm. **(Add.)**

3.4.1 Where electroless nickel plating is specified for corrosion protection, local overlays or bushing may be used as an alternative after the Purchaser approval. The following areas would need protection:

- Adjacent to seat rings and seat springs (seat pockets)
- Adjacent to stem seal (if seal is an "O" ring). **(Add.)**

4.1.3 Ball Valves

4.1.3.1 The body construction shall be one of the following types:

- a)** Top entry with flanged or butt-welding ends. Joint material shall be approved by the Purchaser.
- b)** Split type with one or more bolted flanged joints and with flanged ends joint material shall be approved by
the Purchaser.
- c)** Fully welded spherical body with flanged or butt welding ends. Fabrication from plate is not permitted. **(Add.)**

SECTION TWO**SUPPLEMENT TO BS 5351 (1986, AMDT 1990)****1. Scope**

Add the following paragraphs to existing clause:

This specification applies to flanged, butt welded and threaded end ball valves, reduced and full bore, soft and metal seated, carbon steel, low and high alloy steel nickel alloy, nickel/copper alloy, aluminum alloy and copper alloy valves in nominal size and PN (ANSI) rating, generally in accordance with BS 5351. This document is a supplement to the pertaining design standard and shall be governing where conflict occurs.

For nickel alloy, nickel/copper alloy, aluminum alloy and copper alloy valves, BS 5351 and this supplement shall only be the guidance for the design, dimension and marking. **(Mod.)**

SECTION TWO : DESIGN AND MATERIALS

8. DESIGN

8.1 General

Pressure class, size range and body construction for different type of material shall be as follows:

a- CARBON STEEL, LOW ALLOY AND HIGH ALLOY STEEL

ENDS	BORE	PRESSURE RATING PN (ANSI RATING)	NOM. SIZE DN (NPS)	BODY
Flanged	Red	20-50-100 (150-300-600)	15 up to incl. 250 (½ - 10)	One piece
		20-50-100 (150-300-600)	50 up to incl. 300 (2 - 12)	One or two pieces
	Full	20-50-100 (150-300-600)	15 up to incl. 300 (½ - 12)	One or two pieces
B.W.	Red or	20-50-100 (150-300-600)	50 up to incl. 300 (2 - 12)	One or
	Full			two pieces
Threaded	Red	(800) 8 up to incl. 40 (¼ - 1½)		One piece

b- NICKEL ALLOY AND NICKEL / COPPER ALLOY

Flanged	Red	20-50 (150-300)	15 up to incl. 250 (½ - 10)	One piece
		20-50 (150-300)	150 up to incl. 300 (6 - 12)	One or two pieces
	Full	20-50 (150-300)	15 up to incl. 300 (½ - 12)	One or two pieces
Threaded	Red	(600/800)	8 up to incl. 40 (¼ - 1½)	One piece

c- ALUMINUM ALLOY

Flanged	Red	20 (150)	15 up to incl. 150 (½ - 6)	One piece
---------	-----	----------	----------------------------	-----------

d- COPPER ALLOY

Flanged	Red	20 (150)	15 up to incl. 40 (½ - 1½)	One piece
			50 up to incl. 150 (2 - 6)	One or two pieces
Threaded	Red	64 (400)	8 up to incl. 40 (¼ - 1½)	One piece

Screwed body /cover connection is not acceptable.

(Sub.)

8.4 Flanged Ends

8.4.1 End flanges or stubs of nickel alloy, nickel/copper alloy, aluminum alloy and copper alloy valves shall be cast or forged integral with the body or body connector, unless attachment by welding is approved by the Purchaser. (Add.)

8.5 Stems, Ball Shanks, Stem Extensions

8.5.1 The stem shall be sized such that both its smallest cross section and connection to the ball are capable of withstanding the maximum torque required to operate the valve against the maximum specified differential pressure. (Add.)

8.5.2 The design of valve stem, ball and operating mechanism shall be such that ball and operating mechanism have only "one" unique position after assembly. Any stem extension or actuator shall not influence this requirement. (Add.)

8.6 Stem retention

8.6.1 The anti blow-out stem/body configuration shall be capable of withstanding the full internal pressure of the valve as per the appropriate class. (Add.)

8.6.2 Stem retention by means of body/stem thread is not acceptable. (Add.)

8.6.3 The stem retainer ring or collar shall be integral with the stem. (Add.)

8.6.4 The stem retention shall be designed as a proper (axial) bearing, unless a proper bearing has been incorporated in a different manner. (Add.)

8.7 Gland

8.7.1 A lantern ring is not allowed, unless specified otherwise. (Add.)

8.7.2 The dimension of a stuffing box shall be based on square section packing of a nominal width of not less than 3 mm and shall have a minimum depth to two packing rings. (Add.)

8.7.3 The bottom of a stuffing box shall be flat. (Add.)

8.7.4 The gland shall be adjustable. (Add.)

8.7.5 The maximum diametral clearance between the stuffing box diameter and the outside diameter of the gland (follower) shall be half the actual diametral clearance between the inside diameter of the gland (follower) and the stem diameter. (Add.)

8.8 Body seat rings

The following sentence shall be added to existing clause.

Seat for all metal seated and soft (resilient) seated of trunnion mounted valves shall be capable of withstanding in either flow direction. (Mod.)

8.9 Ball

8.9.1 The ball shall be of a trunnion mounted or other individually supported design in the following sizes:

BORE (REDUCED OR FULL)	PN (ANSI RATING)	NOM. DIAMETER DN (NPS)
Reduced bore	20 and 50 (150 and 300)	300 and larger (12 and larger)
Full bore	20 and 50 (150 and 300)	250 and larger (10 and larger)
Reduced bore	100 (600)	100 and larger (4 and larger)
Full bore	100 (600)	100 and larger (4 and larger)

(Add.)

8.9.2 The ball shall be capable of withstanding the maximum differential pressure, in either flow direction, as per the appropriate class. **(Add.)**

8.9.3 Reduced bore valves shall have a circular or cylindrical ball port. **(Add.)**

8.9.4 Balls shall be of the solid type, unless other types are approved by the Purchaser. **(Add.)**

8.9.5 An integral ball/stem design for seat supported (floating) ball valve is not acceptable. **(Add.)**

8.10 Wrenches and Hand wheels

8.10.1 Wrenches shall have a fixing bolt and/or nut.

8.10.2 Provision for mounting a "Lever lock" type wrench, shall be incorporated in the valve design. This wrench shall be interchangeable with the standard non-locking wrench. **(Add.)**

8.13 Cavity Relief

8.13.1 Trunnion mounted valves shall have the construction of the body seat rings or ring assemblies such that body cavity relief is possible. **(Add.)**

8.13.2 Self-relieving seat rings shall relieve at a body cavity differential pressure not exceeding 30% of the rated pressure at 38°C (100 °F) as per the appropriate class. **(Add.)**

8.13.3 A pressure relief hole in the ball, body or seat is not allowed. **(Add.)**

8.14 For Split Body Construction.

The body split shall be outside the plane of the stem protrusion, unless symmetrical body splits are approved by the Purchaser. **(Add.)**

Body insert shall be of the threaded type and shall have a primary seal close to the seat and a secondary seal at the landing with the body. The landing arrangement shall be such that assembly tolerances are eliminated. **(Add.)**

10.1.1 The following sentence shall be added to existing clause.

Bodies fabricated from plate material are not acceptable. **(Mod.)**

Note to Users

The IPS Standards reflect the views of the Iranian Ministry of Petroleum and are intended for use in the oil and gas production facilities, oil refineries, chemical and petrochemical plants, gas handling and processing installations and other such facilities.

IPS publications are based on internationally acceptable standards and include selections from the options stipulated in the referenced standards. They are also supplemented by additional requirements and/or modifications based on the experience acquired by the Iranian Petroleum Industry and the local market availability. The options which are not specified in the text of the standards are itemized in data sheet/s, so that, the user can select his appropriate preferences therein.

The IPS standards are therefore expected to be sufficiently flexible so that the users can adapt these standards to their requirements. However, they may not cover every requirement or diversity of conditions of each project or work.

For such cases, an addendum to IPS Standard shall be prepared by the user which elaborates the particular requirements of the user. This addendum together with the relevant IPS shall form the job specification for the specific project or work.

The users of IPS publications are therefore requested to send their views and comments, including any addendum prepared for particular cases to the Ministry of Petroleum, Standards and Research Organization. These comments and recommendations will be reviewed by the relevant technical committee and will be incorporated in the formal revision of the relevant IPS. The IPS publications are reviewed and revised approximately every five years.

IRANIAN PETROLEUM STANDARDS

No. 19, Street 14, North kheradmand Karimkhan Avenue, Tehran, Iran

Tel: 66153055

88810460

Fax: 88810462

Email: petrostand@nioc.org